

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150113-R13240  
**Report Reference** R13240-20150106  
**Issue Date** 2015-JANUARY-13

**Issued to:** HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC  
5400 S 122ND EAST AVE, TULSA OK 74146-6007

**This is to certify that  
representative samples of** FILL, VOID OR CAVITY MATERIALS  
one part sealant designated as FS-ONE MAX Intumescent  
Sealant for use in through-penetration firestop systems and  
joint systems


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 1479 - Fire Tests of Through-Penetration  
Firestops  
CAN/ULC-S115 - Method of Fire Tests of Firestops  
Systems

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

