



eco-INSTITUT Germany GmbH

Laborprüfung
Laboratory testing

eco-INSTITUT, Schanzenstr. 6-20, Carlswerk 1.19, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH

Hiltistrasse 6
D - 86916 Kaufering

Dear Sirs / Madames,

based on the evaluation of Test report **60053-A001-AgBB-L** dated **30/07/2025**, for the product **CFS-B**, commissioned by **Hilti Entwicklungsgesellschaft mbH**, we confirm compliance with the requirements of:

- VOC product emissions acc. to DIN EN 16516:2020-10 and LCI values from Table 1 of the AgBB Scheme 2024 after 28 days

These criteria meet the requirements for low-emitting **Insulation** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System for projects outside the US.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Loading factor	Individual VOCs of Concern		Formaldehyde		TVOC (EN 16516)
	Requirement	Requirement hold	Requirement	Requirement hold	Range
0,007 m ² /m ³ for very small surfaces	< LCI	yes	≤ 10 µg/m ³	yes	≤ 0.5 mg/m ³

Mass per surface area: not applicable

Cologne, 30/07/2025

Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project management)



Nach DIN EN ISO/IEC 17025 akkreditiertes Prüflabor

